


		AHU 3.5		AHU 3.6		AHU 3.7		AHU 3.10		AHU 3.11		AHU 5.1	TOTAL
		SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	
		SFINV3_5	RFINV3_5	SFINV3_6	RFINV3_6	SFINV3_7	RFINV3_7	SINV3_10	RINV3_10	SINV3_11	RINV3_11	SFINV5_1	
NOVEMBER	(Starting) 31 Oct, register	0,0	11.497,8	65.409,9	9.594,8	194.578,7		743.301,5	168.945,2	767.313,9	150.768,6	258.399,5	
	28 Nov, register	173,9	11.530,7	65.493,8	9.615,6	194.679,1		745.061,8	169.401,1	768.575,0	150.939,7	259.373,2	
	New consumption KWh	173,9	32,9	83,9	20,8	100,4	20,9	1.760,3	455,9	1.261,1	171,1	973,7	7.476,3
	Operation time	160,0		160,0		170,0		672,0		390,0			
	Old consumption KWh	416,0	59,2	416,0	59,2	1.224,0	255,0	5.241,6	1.008,0	4.875,0	780,0	1.153,8	22.991,4
	Savings KWh	242,1	26,3	332,1	38,4	1.123,6	234,1	3.481,3	552,1	3.613,9	608,9	180,1	15.515,1
												Savings % →	67,5

		AHU 3.5		AHU 3.6		AHU 3.7		AHU 3.10		AHU 3.11		AHU 5.1	TOTAL
		SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	
		SFINV3_5	RFINV3_5	SFINV3_6	RFINV3_6	SFINV3_7	RFINV3_7	SINV3_10	RINV3_10	SINV3_11	RINV3_11	SFINV5_1	
December	(Starting) 28 Nov, register	173,9	11.530,7	65.493,8	9.615,6	194.679,1		745.061,8	169.401,1	768.575,0	150.939,7	259.373,2	
	31 Dec, register	291,7	11.551,1	65.587,9	9.633,4	194.721,9		747.618,4	170.016,2	771.097,1	151.258,5	260.296,1	
	New consumption KWh	117,8	20,4	94,1	17,8	42,8	8,9	2.556,6	615,1	2.522,1	318,8	922,9	8.799,6
	Operation time	106,6		106,6		81,7		816,0		463,4			
	Old consumption KWh	277,2	39,4	277,2	39,4	588,2	122,6	6.364,8	1.224,0	5.792,5	926,8	1.172,1	20.892,2
	Savings KWh	159,4	19,0	183,1	21,6	545,4	113,7	3.808,2	608,9	3.270,4	608,0	249,2	12.092,6
											Savings % →		57,9
JANUARY	(Starting) 31 Dec, register	291,7	11.551,1	65.587,9	9.633,4	194.721,9		747.618,4	170.016,2	771.097,1	151.258,5	260.296,1	
	31 Jan, register	406,8	11.573,8	65.645,9	9.647,2	194.823,8		749.799,4	170.481,7	774.028,3	151.616,7	261.226,1	
	New consumption KWh	115,1	22,7	58,0	13,8	101,9	21,2	2.181,0	465,5	2.931,2	358,2	930,0	9.086,8
	Operation time	136,4		136,4		165,6		744,0		475,2			
	Old consumption KWh	354,6	50,5	354,6	50,5	1.192,3	248,4	5.803,2	1.116,0	5.940,0	950,4	1.593,9	23.175,6
	Savings KWh	239,5	27,8	296,6	36,7	1.090,4	227,2	3.622,2	650,5	3.008,8	592,2	663,9	14.088,9
											Savings % →		60,8

		AHU 3.5		AHU 3.6		AHU 3.7		AHU 3.10		AHU 3.11		AHU 5.1	TOTAL
		SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	RETURN	SUPPLY	
		SFINV3_5	RFINV3_5	SFINV3_6	RFINV3_6	SFINV3_7	RFINV3_7	SINV3_10	RINV3_10	SINV3_11	RINV3_11	SFINV5_1	
FEBRUARY	(Starting) 31 Jan, register	406,8	11.573,8	65.645,9	9.647,2	194.823,8		749.799,4	170.481,7	774.028,3	151.616,7	261.226,1	
	28 Feb, register	505,7	11.592,0	65.697,7	9.658,1	194.919,6		752.241,3	170.998,8	776.089,9	151.853,6	262.200,4	
	New consumption KWh	98,9	18,2	51,8	10,9	95,8	19,9	2.441,9	517,1	2.061,6	236,9	974,3	8.063,9
	Operation time	104,3		99,3		184,2		672,0		441,2			
	Old consumption KWh	271,2	38,6	258,2	36,7	1.326,2	276,3	5.241,6	1.008,0	5.515,0	882,4	1.409,4	21.114,7
	Savings KWh	172,3	20,4	206,4	25,8	1.230,4	256,4	2.799,7	490,9	3.453,4	645,5	435,1	13.050,8
											Savings % →		61,8
MARCH	(Starting) 28-02-2017, register	505,7	11.592,0	65.697,7	9.658,1	194.919,6		752.241,3	170.998,8	776.089,9	151.853,6	262.200,4	
	31-03-2017, register	741,7	11.633,9	65.805,5	9.682,3	195.028,1		753.951,7	171.363,1	778.574,6	152.084,4	263.171,7	
	New consumption KWh	236,0	41,9	107,8	24,2	108,5	22,5	1.710,4	364,3	2.484,8	230,8	971,3	8.802,1
	Operation time	246,2		250,8		242,9		744,0		478,8			
	Old consumption KWh	640,1	91,1	652,1	92,8	1.748,9	364,4	5.803,2	1.116,0	5.985,0	957,6	1.539,8	25.762,1
	Savings KWh	404,1	49,2	544,3	68,6	1.640,4	341,9	4.092,8	751,7	3.500,3	726,8	568,5	16.960,0
											Savings % →		65,8

Air Handling Units
Energy Saving
(KWh)



Air Handling Units
Energy Saving
%

